



DETAIL A

****AS REQUIRED ITEMS ARE NOT INCLUDED****

NOTES

- Strip item 1 insulation off approx. 300mm below finished surface level.
- Equipotential personal protective bond attachment point.

TIMBER POLE BUTT EARTHING			Quantities Required
Item	Description	CAT No.	
1	CABLE 70mm 19/2.14 SDI BLACK Cu	442770	AS REQD
2	SADDLE 16mm GALV	111710	8
3	BATTEN PLASTIC EARTH 3000mm PVC	267600	1
4	SCREW 12Gx40mm TEK GALV H/H	101900	AS REQD
5	POLE STEP SCREW IN	275850	1

AMENDMENT DETAILS

8	DRAWN	NR
	CHCKD	DP/SP
	DATE	15/11/2019
REMOVED SPLIT BOLTS & MODIFIED DIMENSIONS OF LOOP. UPDATED NOTES.		
7	DRAWN	SG
	CHCKD	DP/SP
	DATE	11/01/2016
DRAWING BORDER REVISED. QR CODE ADDED. NOTE '4' REF ON DRAWING WAS NOTE '5'.		
6	DRAWN	SG
	CHCKD	DP/SP
	DATE	11/10/2013
NOTE 1 REMOVED. NOTES 2 TO 6 RENUMBERED AS 1 TO 5.		



SCALE	NTS
ISSUED	01/06/2005
DRAWN BY	LRW
CHECKED BY	S. PALMER
AUTHORISED BY	
<i>Deepak Pais</i>	
PRINCIPAL ENGINEER OVERHEAD CONSTRUCTION STANDARDS	
DATE	15/11/2019

CEOM7109.04

1 of 1 A4

TIMBER
POLE
BUTT
EARTH
CONNECTION

